

## **LNG Road Tanker Emergency**

## **Operational Guidelines**

#### **NATURAL GAS**

- Natural Gas is odourless, colourless, non-corrosive, non-toxic, and lighter than air so it dissipates quickly
- Mercaptan is added to give it a rotten egg smell
- Natural gas ignites only when the gas to air ratio is between 5% and 15%

#### LNG

- LNG is **clear**, **odourless**, **colourless**, and cooled to -162° Celsius
- LNG is a cryogenic liquid, and is not pressurized like CNG
- Spilled LNG will evaporate into odourless natural gas

CAUTION – liquefied natural gas (UN 1972) IS NOT ODORIZED

Notify FortisBC of any LNG road tanker emergency 1-877-889-2002 DO NOT attempt to move the tanker or operate the equipment prior to an inspection by a FortisBC LNG Subject Matter Expert











FortisBC Tanker Specifications

NOTE: Not all tankers transporting LNG arc op

### Si

round the province <u>are owned</u> and perated <u>by FortisBC</u> .	anni)
Specifications	William Co.
ength.	40 feet 7 inches

### **ISO Unit**



### **Alloy Custom Tanker T3**



40 feet 7 inches	49 feet 3 inches
150 inches	151 inches
32,617 lbs.	25,940 lbs.
8 feet	8 feet
37,825 lbs	40,227 lbs.
76,200 lbs.	68,000 lbs.
12,162 US Gallons	12,880 US Gallons
Carbon Steel	Carbon Steel and Stainless Steel
SA 240 Type 201 Stainless Steel	SA 240 Type 304 Stainless Steel
114 PSI	70 PSI
Two Mains—114 psi	Mains—70psi, Secondary—105 psi
No	No
2280 Hours (95 Days)	636 Hours (26.5 Days)
	150 inches 32,617 lbs. 8 feet 37,825 lbs 76,200 lbs. 12,162 US Gallons Carbon Steel SA 240 Type 201 Stainless Steel 114 PSI Two Mains—114 psi No


# LNG Transportation Emergency Operational Guidelines

These procedures are to be used when responding to an incident involving a tanker transporting Liquefied Natural Gas (LNG)

These operational guidelines are not to supersede existing department procedures and are meant as suggested actions not explicit instructions







These Operational Guidelines are suggested actions only. Each incident must be evaluated separately and then responded to safely, using appropriate methods and procedures.

FortisBC guidelines <u>do not</u> supersede your departmental procedures.